Grading Plan Approved
as shown and/or noted
THOMAS P. GILLES, P.E.
Lake County Engineer
By GJH Date 9.27.93
ODOT PERMIT REQUIRED

NORTH
SCALE 1"=20'

EXISTING CEMETERY

SEWAGE DISPOSAL PERMIT MUST BE OBTAINED BY A LAKE COUNTY LICENSED INSTALLER BEFORE INSTALLATION IS STARTED.

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover
B. No footer drains or downspouts to be discharged into septic tanks
C. All waste water to be discharged into septic tanks

LOW YIELD WATER EXTURES REQUIRED ON ALL:
— Shower Head
— Toilet

EXIST. ELEV.
PROP. ELEV.
EXIST. CONTOUR
PROP. CONTOUR

EXISTING WOODS
(POPULATION AREA)

DOWNSPOUTS & FOOTER DRAINS TO DISCHARGE INTO RAVINE

DEEP RAVINE

500 Sq. Ft. Subsurface Sand Filter 20'x 30'

EAST SEPTIC SYSTEM AREA (ALTERNATE)

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date 9-24-93
JOEL LUCIA, R.S., M.P.H.
Health Commissioner
By Harold B. Moore

#0993-7606
ZONING PERMIT
ISSUED 9-17-93
SUBJECT TO APPROVAL BY:
Lake County Sanitary Eng. ☐
Lake County Eng. Dept. ☒
Lake County Planning Comm. ☐
Lake County Bldg. Dept. ☒

I, the undersigned hereby certify that this topography, indicated by 1' contours and elevations shown hereon represent an actual field survey made by me on September 22, 1993 and that the elevations were taken at appropriate intervals and that on of that data they witness an accuracy as indicated hereon.

No boundary survey performed by P. Gerson or William R. Gray Associates, Inc., for determinations taken from previous survey by T. Conway, P.S. #5817.

WILLIAM R. GRAY ASSOCIATES, INC.
7510 MENTOR AVENUE, MENTOR, OHIO 44060 (216) 946-7900

Well Site Plan - 9.1
Castoro Subdivision
Concord Twp. - Lake County
Vacant Parcel - 1.41 Acres ±
233-23-93

Med Plus
Doug Dimmerman
7302 Hopkins, Rd.
Mentor, Ohio

1/2