SITE PLAN
FOR
ROBERT WIENHOLD
BEING PART OF LOT No. 72, IN THE TOWNSHIP OF LEROY, LAKE COUNTY, OHIO.

SCALE: 1" = 30'

N

EXIST.
PROP.
EXIST.
PROP.

I, the undersigned hereby certify this topography, indicated by 1' contours, and elevations shown hereon represent an actual field survey by me on MARCH 16, 1995 and that the were taken at appropriate intervals and that as of that date they existed as indicated hereon.

Thomas M. Coffman P.S.
No. 6857

STATE OF OHIO
THOMAS M. COFFMAN
No. 6857

APRIL 7, 1995
REV 5-31-95 (WELL)

FRANK KOVACIC
VOL 817-1151

N 89°37'00"E 960.62'

20' x 12' CHP (FIELD SET)

GRAVEL D/W

60'

100'

ROOF WELL

20' GAR. 16.6

10

FF 100.25
BSMT 11.58

S8-100.5'

135'S.B

DUPLICATION AREA

8" EST @ 125'

ROBERT & LINDA M. WIENHOLD
VOL 455-665
4.7475 AC

C.W. & M. HILLER
VOL 250-318

HILL RD

PAINE ROAD

NORTH 200.00'

82'

4" PVC DRAIN (EXPOSURE)

4" PVC ROOF DRAIN (EXPOSURE)

S 89°37'00"W 1077.41'

MA & S.A. GODFREY
VOL 685-728

1054'S TO ℄ PINEY HOLLOW LN.

FF-100.25

EXIST. WELL

★ GRINDER PUMP REQUIRED IF PLUMBING IN BSMT

BSMT - 91.58

HYDRAULIC PROFILE
VERT. 1" = 3' HORZ 1" = 30'
3 BEDROOM HOME

1000 GAL TANK 95.4

1000 GAL TANK 95.2

SPLITTER INV 95.0

DIST BOX INV 94.8

DIST BOX INV 93.8

4" PVC CURTAIN DRAIN

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover

B. No footer drains or downspouts to be discharged into septic tanks

C. All waste water to be discharged into septic tanks

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date 6-2-95
JOEL LUCIA, R.S., M.P.H.
Health Commissioner
BY J. Lindsay

LEROY TOWNSHIP
Zoning Approved
#2227
Zoning Inspector

LOW YIELD WATER FIXTURES REQUIRED ON ALL:
Shower Head
Toilet

EVAPORATION-TRANSPIRATION TRENCH DETAIL

CURTAIN DRAIN DETAIL

Grading Plan Approved
as shown and/or noted
THOMAS P. GILLES, P.E.
Lake County Engineer
By GJH Date 6 14 95

SEWAGE DISPOSAL PERMIT MUST BE OBTAINED BY A LAKE COUNTY LICENSED INSTALLER BEFORE INSTALLATION IS STARTED.

VILLAGE SURVEYING CO.
P.O. BOX 1096 FAIRPORT HARBOR, OHIO. 44077
(216) 357-1359