SITE PLAN

MADISON TOWNSHIP LAKE COUNTY, OHIO

for: CHARLES LEET
CLIENT OWNER

ADDRESS STREET CITY ZIP

MEADOW WOOD ALLOTMENT SUBDIVISION M-5 NAME VOL. – PG.
7 SUBLOT NO. MEADOW WOOD DR. STREET
LOT TRACT
VOLUME PAGE
PERM. PARCEL NO. STREET

LEGEND

SANITARY MANHOLE
STORM MANHOLE
INLET OR CATCH BASIN
HYDRANT
EXISTING CONTOURS
PROPOSED CONTOURS
EXIST. ELEV. 100.0 / 100.0 PROP. ELEV.
WATER VALVE (GAS)
WATER METER (GAS)
AS BUILT ELEVATION 100.0
INDICATES DIRECTION OF SURFACE DRAINAGE

REMARKS

ALL BOUNDARY DATA SHOWN WAS OBTAINED FROM (DEEDS, RECORDED SUBDIVISION PLAT OR OTHER PUBLIC RECORDS)

LOCATIONS AS SHOWN OF ADJACENT WELLS AND SEPTIC TANKS OBTAINED FROM LAKE COUNTY HEALTH DEPARTMENT

DESIGN CERTIFICATION

THIS PLAT WAS PREPARED BY ME, AND IS CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF.

Edward W. Fiveash PS 6148
NAME SURVEYOR REGISTRATION NO.

CHECK LIST

NO. OF BEDROOMS
DIMENSIONS
BEARINGS
TIE TO NEAREST STREET
SUBLOT NO. PARCEL NO.
SURROUNDING OWNERS
BLDG. DIMENSIONS FIN. GR.
BLDG. TIES FL'R. GRADES
APRON TYPE WIDTH THICKNESS
SIDEWALK TYPE WIDTH THICKNESS
CULVERT TYPE DIA. LENGTH
ROCK OUTCROPPINGS
WATER MAIN SIZE, LOCATION
SAN. SEWER SIZE % GR. LOC.
SAN. MH. CAST. ELEV. INV. ELEV.
SAN. CONN. SIZE, LOC. DEPTH
STORM SEWER SIZE % GR. LOC.
STORM MH. CAST ELEV. INV. ELEV.
PAVT TYPE GRADE CURBS
GAS LINE LOC. SIZE PRESSURE
SEPTIC TANK LOCATION & DUPLICATION AREA
WELL LOCATION
ISOLATION RADIUS FROM WELL

REVISIONS					
NO.	DATE	BY			
1			PLAN PREPARED BY: DEBEVEC · SALO & ASSOCIATES, INC. PAINESVILLE, OHIO		
2					
3			DRAWN BY RK	SCALE 1" = 30'	PHONE NO. 352-9250
4			CHK'D	DATE 11 MAY 77	DRAWING NO. 4828-7
5			CREW CHIEF	APP'D	

NORTH

NORTH 89° 36' 00" EAST 151.93'

DUPLICATION AREA

100' FLOW LINE = 92.6

DISTRIBUTION BOX

SPLITTER

2-1000 GAL. SEPTIC TANKS

600' L.F. BEACH FIELD

100' FLOW LINE = 92.6

S/L 7

SLAB FIN. FLOOR 101.35

GARAGE FIN FLR 100.93

50.00' SETBACK

EXISTING HOUSE

SOUTH 0° 11' 00" EAST 245.42'

NORTH 0° 02' 00" EAST 243.00'

60' SETBACK

PROPOSED WELL 100' ISOLATION RADIUS

PROPOSED DRIVE CULVERT

RADIUS = 50.00'

EXISTING SWALE

18' MACADAM PAVEMENT

SOUTH 89° 36' 00" WEST 186.89'

990.00' TO CENTERLINE OF GREEN ROAD

EXISTING SWALE

MEADOW WOOD DRIVE 60'

PROFILE
NO SCALE

FIN. FLOOR 101.35
FIN. GROUND 100.6
SEPTIC TANK
SPLITTER
DISTRIBUTION BOX
FLOW LINE = 92.6

Grading Plan Approved as shown and/or noted
THOMAS P. GILLES, P.E.
Lake County Engineer
By D.J.L. Date 5/13/77

Zoning Permit # 9855

"AS BUILT" CERTIFICATION

I, HEREBY CERTIFY THAT THE CIRCLED GRADES ARE EXISTING FINISH GRADES CHECKED IN FIELD ON 19 BY SURVEYING AND ARE CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF.

REGISTERED SURVEYOR REG. NO.

Reviewed and Accepted
LAKE COUNTY COMBINED GENERAL DISTRICT DEPARTMENT OF HEALTH
Date 5-13-77
FRED C. KLUTH, M. D.
Health Commissioner
By

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover
4. Vent Pipes
B. No footer drains or downspouts to be discharged into septic tanks
C. All waste water to be discharged into septic tanks

4828-7