SITE PLAN

MADISON — LAKE COUNTY, OHIO
TOWNSHIP

for: BRIAN L. HANUSOSKY
CLIENT OWNER

5414 RIVER ROAD, MADISON 44057
ADDRESS STREET CITY ZIP

SUBDIVISION	NAME	LOT 724	TRACT 201 5
SUBLOT NO.	VOL. PG. STREET	VOLUME IA PERM. PARCEL NO. 7	PAGE 18 STREET RIVER ROAD

LEGEND

SANITARY MANHOLE
STORM MANHOLE
INLET OR CATCH BASIN
HYDRANT
EXISTING CONTOURS
PROPOSED CONTOURS
EXIST. ELEV. 100.0
PROP. ELEV. 100.0

WATER VALVE (GAS)
WATER METER (GAS)
AS BUILT ELEVATION (780)
INDICATES DIRECTION OF SURFACE DRAINAGE

REMARKS

ALL BOUNDARY DATA SHOWN WAS OBTAINED FROM (DEEDS, RECORDED SUBDIVISION PLAT OR OTHER PUBLIC RECORDS)

LOCATIONS AS SHOWN OF ADJACENT WELLS AND SEPTIC TANKS OBTAINED FROM LAKE COUNTY HEALTH DEPARTMENT

DESIGN CERTIFICATION

THIS PLAT WAS PREPARED BY ME, AND IS CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF.

NAME SURVEYOR REGISTRATION NO.

Grading Plan Approved as shown P. GILLES, P.E. THOMAS P. GILLES, P.E. Lake County Engineer Date 22 Jan 83

By: [illegible]

SCALE - 1" = 40'

NORTH

N 30° 27' E 1209.90'

S 63° 37' W A-363.35' C-363.35' R-12432.66'

S 64° 22' W 368.57'

S 30° 22' W 978.70'

INTERSTATE 90 (S.R. 11)

1878.08' (RECORD) TO THE MADISON - PERRY TOWNSHIP LINE

N 82° 00' E 648.78'

(S. R. 307)

RIVER ROAD

60'

EXISTING DITCH

EXISTING 20' ASPHALT PAVEMENT

EXISTING 8" WATER MAIN

PROPOSED 8" WATER MAIN

EXISTING BARN 62'

EXISTING BARN DRIVE

SETBACK

DUPLICATION AREA

1000 L.F. EVAPO-TRANSPIRATION SYSTEM

INV. 808.00 GRADE

INV. 807.00 GRADE

INV. 806.00 GRADE

INV. 805.00 GRADE

INV. 804.00 GRADE

INV. 803.00 GRADE

INV. 802.00 GRADE

INV. 801.00 GRADE

2-1000 GALLON SEPTIC TANKS

SPLITTER

DISTRIBUTION BOXES

NOTE: EXISTING DRIVE TO BE EXTENDED TO NEW RESIDENCE

PROPOSED WATER CONNECTION

BENCHMARK (T.B.M.) - NAIL IN POWER POLE ELEVATION - 816.20

130.0' SETBACK

EXISTING STONE DRIVE

EXISTING HOUSE

SETBACK

PROPOSED NEW PARCEL

EXISTING WATER STORAGE TANK

EXISTING WELL

100' ISOLATION RADIUS

152'

PERMANENT PARCEL 1A - 18 - (7)

INSPECTION WELL MIN. 8" DIA. WITH SECURED COVER EXTENDED ABOVE GRADE FOR USE BY ADJACENT LOTS

CURTAIN DRAIN TRENCH

TYPICAL SECTION SCALE 1/2" = 1'-0"

8'-0" MIN.

12" MIN.

24" MIN.

TOPSOIL (12" MIN.)

3" RIGID, 3 HOLE PERFORATED (EQUAL TO PLASTIC) PIPE

3/4" GRAVEL

SAND

2" MIN. TO 4" MAX.

EVAPO-TRANSPIRATION TRENCH

HYDRAULIC PROFILE

SCALES

HORIZONTAL 1" = 50' / VERTICAL 1" = 5'

EXISTING GROUND

PROPOSED GROUND

SEWAGE SYSTEM MUST BE INSPECTED BY HEALTH DEPARTMENT BEFORE COVERING.

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover
4. Vent Pipes
B. No footer drains or [illegible] to be discharged into septic tanks
C. All inside water to be discharged into septic tanks

Expires Six Months From Date of Issue unless authorized work is commenced or extension granted.
First 90 day extension
Second 90 day extension

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date 6-17-83
JOEL LUCIA, R.S., M.P.H.
Health Commissioner
By [illegible]

SEWAGE DISPOSAL PERMIT MUST BE OBTAINED BY A LAKE COUNTY LICENSED INSTALLER BEFORE INSTALLATION IS STARTED.

REVISIONS		
NO.	DATE	BY
1		
2		
3		
4		
5		

PLAN PREPARED BY:
DEBEVEC • SALO & ASSOCIATES, INC.
125 E. ERIE ST. PAINESVILLE, OHIO

DRAWN BY L.L.	SCALE 1" = 40'	PHONE NO. 352-9250	
CHK'D.	DATE JUNE 8, 1983	DRAWING NO. 5943	
		CREW	APP'D.