FOR

TODD MENMUIR

BEING A PART OF LOT NO. 7, TRACT NO 4
IN THE TOWNSHIP OF MADISON, COUNTY OF
LAKE, STATE OF OHIO.

N 1" = 30'

EXIST PROP

EXIST PROP

EXIST HOUSE

EXIST WELL

EXIST SYSTEM

T.C. + L.M. GOLDING
VOL 596-479

N87° 27' 50" W 670.00'

TODD L MENMUIR
VOL 609-918

A.D. SIDLEY
VOL 609-467

S 1°43' 50" W 280.00'

EVAPORATION-TRANSPIRATION TRENCH DETAIL

S87° 27' 50" E 670.00'

R. FRALEY
VOL 614-723
(VACANT)

71.99'

100' R

F.F.-101.8
BSMT-99.13

3 GAL
99.8

98

BET @ 12'

8' TYP

DUPLICATION AREA

w/ Aeration

8' DWJ

71.99'

60
200.00'

N 1°48' 50" E

WOOD RD

12" CMP

S36°7'70

N 1/2 line Contract 3 Tract 4

EF-101.8

GRINDER PUMP REQD IF PLUMBING IN BASEMENT

1000 GAL TANK INV 98.5

1000 GAL TANK INV 98.3

SPLITTER INV 98.2

DIST BOX (L) INV 98.1

98.6

BSMT-99.8

HYDRAULIC PROFILE
VERT 1" = 3' HORZ 1" = 30'
3 BEDROOM HOME

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date 9.16.92
JOEL LUCIA, R.S., M.P.H.
Health Commissioner
BY N. Niemus

SEWAGE DISPOSAL PERMIT MUST BE OBTAINED BY A LAKE COUNTY LICENSED INSTALLER BEFORE INSTALLATION IS STARTED.

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover

B. No footer drains or downspouts to be discharged into septic tanks

C. All waste water to be discharged into septic tanks

Grading Plan Approved as shown and/or noted
THOMAS P. GILLES, P.E.
Lake County Engineer
GJH 4/22/95

APPROVED
MADISON TOWNSHIP ZONING
AUG 18 1995
PERMIT # 14646
ZONING INSPECTOR

LOW YIELD WATER FIXTURES REQUIRED ON ALL:
___ Shower Head
___ Toilet

THOMAS PARKER MILLER
REGISTERED SURVEYOR
OHIO

SEPT 15, 1992

I, the undersigned hereby certify that this topography, indicated by 1' contours, and elevations shown hereon represent the actual field survey made by me on July 9, 1992 and that the elevations were taken at appropriate intervals and that as of that date, they existed as indicated hereon.

J.M. Coffman PS

VILLAGE SURVEYING CO.
202 THIRD ST., FAIRPORT HBR., OH 44077
(216) 357-1359