SITE PLAN

PERRY TOWNSHIP, LAKE COUNTY, OHIO

for: McCULLOUGH BUILDERS
CLIENT / OWNER

ADDRESS STREET CITY ZIP

SUBDIVISION NAME
VOL. – PG.
SUBLOT NO. STREET

69 LOT
Pt. 868 TRACT 388
VOLUME
Pt. 34-15-16 PAGE BLACKMORE
PERM. PARCEL NO. STREET 20

LEGEND

SANITARY MANHOLE
STORM MANHOLE
INLET OR CATCH BASIN
HYDRANT
EXISTING CONTOURS
PROPOSED CONTOURS
EXIST. ELEV. 100.0 / PROP. ELEV. 100.0
WATER VALVE (GAS)
WATER METER (GAS)
AS BUILT ELEVATION (100.0)
INDICATES DIRECTION OF SURFACE DRAINAGE

REMARKS

ALL BOUNDARY DATA SHOWN WAS OBTAINED FROM (DEEDS, RECORDED SUBDIVISION PLAT OR OTHER PUBLIC RECORDS)

LOCATIONS AS SHOWN OF ADJACENT WELLS AND SEPTIC TANKS OBTAINED FROM LAKE COUNTY HEALTH DEPARTMENT

DESIGN CERTIFICATION

THIS PLAT WAS PREPARED BY ME, AND IS CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF.

NAME SURVEYOR REGISTRATION NO. #6343

CHECK LIST

NO. OF BEDROOMS
DIMENSIONS
BEARINGS
TIE TO NEAREST STREET
SUBLOT NO. PARCEL NO.
SURROUNDING OWNERS
BLDG. DIMENSIONS FIN. GR.
BLDG. TIES FL'R. GRADES
APRON TYPE WIDTH THICKNESS
SIDEWALK TYPE WIDTH THICKNESS
CULVERT TYPE DIA., LENGTH
ROCK OUTCROPPINGS

WATER MAIN SIZE, LOCATION
SAN. SEWER SIZE % GR. LOC.
SAN. MH. CAST. ELEV. INV. ELEV.
SAN. CONN. SIZE, LOC. DEPTH
STORM SEWER SIZE % GR. LOC.
STORM MH. CAST ELEV. INV. ELEV.
PAVT TYPE GRADE CURBS
GAS LINE LOC. SIZE PRESSURE
SEPTIC TANK LOCATION & DUPLICATION AREA
WELL LOCATION
ISOLATION RADIUS FROM WELL

REVISIONS		
NO.	DATE	BY
1		
2		
3		
4		
5		

PLAN PREPARED BY:
BABCOCK • JONES & ASSOCIATES, INC.
PAINESVILLE, OHIO

DRAWN BY [illegible] SCALE 1" = 30' PHONE NO. 357-1811
CHK'D. [illegible] DATE 11-20-92 DRAWING NO. 92-107-C
CREW CHIEF KJ APP'D. [illegible]

1) The road ditch is not deep enough to accomodate the certain drain outlet. Lower the ditch about a foot.

2) Lines are 67' long and must be 75' long. Maybe the tanks could go north-south to save a little room. Move septom back to allow for full length of lines. Additional possibility - deeper setback.

Please resubmit after revision.

PARCEL "D" (VACANT)

PARCEL "C" 1.157 AC.

PARCEL "B" (VACANT)

N

505.96' M/L

(386' ±)

DUPLICATION AREA

54.66'

SLAB FF 99.3
BASE FF 98.5
3 BEDROOM
UNDER 22.67'

(22'3½")

2-1000 GAL. SEPTIC TANKS

PROP. DRIVE

WATER

CURTAIN DRAIN

400 L.F. BEACH (115 S.B.)

PROP. 12" CULVERT

I.P. FD.

789.79'

NORTH 100.00'

NORTH RIDGE ROAD

BLACKMORE ROAD - 60'

HYDRAULIC PROFILE
HORZ. 1"=50', VERT. 1"=5'

SPLITTER

2-1000 GAL. SEPTIC TANKS

CURTAIN DRAIN

1.9% ET

LAST ET 96.6

100 95

STATE OF OHIO
HARRY S. JONES, JR.
S-6343
REGISTERED SURVEYOR

Grading Plan Approved as shown and/or noted
THOMAS P. GILLES, P.E.
Lake County Engineer
By GJH Date 12/2/92

ROADSIDE WILL NOT BE LOWERED!

APPROVED
SIDE LINES & SET BACK
PERRY TOWNSHIP ZONING
PERMIT NO. 4719
ZONING INSPECTOR Don King

"AS BUILT" CERTIFICATION

I, HEREBY CERTIFY THAT THE CIRCLED GRADES ARE EXISTING FINISH GRADES CHECKED IN THE FIELD ON _____, 19__ AND ARE CORRECT TO THE BEST OF MY KNOWLEDGE AND BELIEF.

REGISTERED SURVEYOR REG. NO.

TEMP. BENCHMARK: TOP OF HYDRANT PARCEL C"
ELEV. = 101.28

"I, the undersigned, hereby certify that the topography indicated by [illegible] foot contours, and elevations shown hereon represent an actual field survey made by me on the 17th day of Nov., 19 92 and that the elevations were taken at appropriate intervals and that as of that date they existed as indicated hereon."

Name Reg. No. #6343