SITE PLAN
FOR
JOE KOZLOWSKI
BEING A PART OF LOT NO. 73, IN THE TOWNSHIP OF PERRY, LAKE COUNTY, OHIO.

1"=20'

N

EXIST. PROP.

EXIST. PROP.

BENCHMARK - 100.00 (ASSUMED)
NAIL IN POWER POLE

PROP. 12" WATER SCHEDULED CONST. 6-92

EXIST. WELL

GAR - 99.74

14.2'

100'

S 89° 42' 45" E 420.18'

21.84'

RICHARD & CHERYL CAROLUS
VOL 653-723

SEWAGE DISPOSAL PERMIT MUST BE OBTAINED BY A LAKE COUNTY LICENSED INSTALLER BEFORE INSTALLATION IS STARTED.

LOW YIELD WATER FIXTURES REQUIRED ON ALL:
— Shower Head
— Toilet
— _____

CRAWL - 101.7

F.F. - 101.7
BSMT - 93.03

6 @ 75'

DUPLICATION AREA

104.34'

CALL RD. NORTH

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date 6.4.92
JOEL LUCIA, R.S., M.P.H.
Health Commissioner
BY N. Nichus

14.5' ASPHALT

208.66' TR
PERRY VILLAGE LANE

F.F. - 99.18

N 54° 42' 45" W 421.71'

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover

B. No footer drains or downspouts to be discharged into septic tanks
C. All waste water to be discharged into septic tanks

APPROVED
SIDE LINES & SET BACK
PERRY TOWNSHIP ZONING
PERMIT NO. 4632
ZONING INSPECTOR Steve K

MAY 29, 1992

24" MIN.
SOIL (2" MIN)
STRAW
4" RIGID PERF PIPE
3/4" GRAVEL
18"-30"
4'-4"±
LEACH FIELD

F.F. - 101.7

1000 GAL TANK
INV 97.0

1000 GAL TANK
INV 96.8

SPLITTER
INV 96.6

DIST BOX (2)
INV 96.4

* GRINDER PUMP REQ'D. IF PLUMBING IN BASEMENT

BSMT - 93.03

HYDRAULIC PROFILE
VERT - 1" = 3' HORZ - 1" = 30'
3 BEDROOM HOME

I, the undersigned hereby certify that this topography, indicated by 1' contours, and elevations shown hereon represent an actual field survey made by me on 4-27-92 and that the elevations were taken at appropriate intervals and that as of that date they existed as indicated hereon.

J. M. Coffman PS No 6657

Grading Plan Approved
as shown and/or noted
THOMAS P. GILLES, P.E.
Lake County Engineer
By _____ Date 6/8/92

VILLAGE SURVEYING Co
202 THIRD ST. FAIRPORT HBR. OH 44077
(216) 357-1359