FOR

LARRY BRAINARD

BEING SUBLOT NO. 50 OAKBROOK VILLAGE SUB'D., TOWNSHIP OF PERRY, COUNTY OF LAKE, STATE OF OHIO.

Grading Plan Approved
as shown and/or noted
THOMAS P. GILLES, P.E.
Lake County Engineer
By GJH Date 2-1-93

BENCHMARK - 696.52
TOP BOLT HYDRANT - S/L 38

N

1"=20'

EXIST PROD

EXIST PROD

F.F. - 697.90

54'

36.4'

29'

697

696

695

694

N 79° 44' 43" E 202.90'

4" CURTAIN DRAIN

1 STY. 3 BEDROOM SUB
F.F. 697.95

GOO LEACH TOTAL

CURTAIN DRAIN DETAIL

CURVE DATA - X

RADIUS -	1163.95'
ARC -	97.63'
CHORD -	97.60'
BEARING -	N12° 39' 31"W

16' CONC D/W

CHORD - 697.2

OAKBROOK DR. 60'

S 74° 56' 15" W 116.19'

50' S.B. LINE

N 15° 03' 45" W 27.00'

24" MIN

TOPSOIL (2" MIN)

STRAW

4" RIGID PERF PIPE

3/4" GRAVEL

LEACH FIELD

HYDRAULIC PROFILE
VERT - 1" = 3' HORZ - 1" = 30'

F.F. - 697.95

1000 GAL. TANK INV. 694.5

1000 GAL. TANK INV. 694.1

STRAINER INV. 693

(2) DIST. BOX INV. 694.4

SEWAGE DISPOSAL PERMIT MUST BE OBTAINED BY A LAKE COUNTY LICENSED INSTALLER BEFORE INSTALLATION IS STARTED.

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date 1-28-93
Duplication by aeration to storm
JOEL LUCIA, R. S., M. P. H.
Health Commissioner
BY N. Nichus

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover

B. No footer drains or downspouts to be discharged into septic tanks

C. All waste water to be discharged into septic tanks

LOW YIELD WATER FIXTURES REQUIRED ON ALL:
___ Shower Head
___ Toilet
___ _____

APPROVED
SIDE LINES & SET BACK
PERRY TOWNSHIP ZONING
PERMIT NO. 4738
ZONING INSPECTOR Jim King

STATE OF OHIO
THOMAS MARC COFFMAN
6857
REGISTERED SURVEYOR

I, the undersigned hereby certify that this topography, indicated by 1' contours, and elevations shown hereon represent an actual field survey made by me on Dec. 8, 1992 and that the elevations were taken at appropriate intervals and that as of that

J. M. Coffman PS
No. 6857

Rev Jan 21, 1993

VILLAGE SURVEYING CO.
202 THIRD ST. FAIRPORT HBR., OH 44077
(216) 357-1359