SITE PLAN
FOR
ANGELDRO CONST. CO.
BEING PARCEL '3' OF COLLINS SPLIT
SOUTH RIDGE RD. IN THE TOWNSHIP OF
PERRY, COUNTY OF LAKE, STATE OF OHIO

1" = 20'

EXIST PROP.

EXIST PROP.

BENCHMARK - 100.00 (ASSUMED)
NAIL IN POWER POLE #5515 PHEEL '15'

S 27° 30' 00" E 309.10'

N 24° 09' 54" E 100.04'

PARCEL '3' 0.7131 Ac

N 27° 30' 00" W 312.04'

S 62° 30' 00" W

SOUTH RIDGE RD. 60' 100.00

PROPOSED DUPLICATION AREA

GAR 100.8

16' CONC D/W

PROP. WELL
Municipal water purpose

3BR SLAB
F.F. = 101.55

FF-101.55

5' TYP

6 @ 75'

HYDRAULIC PROFILE
VERT 1" = 3' HORZ 1" = 30'
3 BEDROOM

DIST BOX INV 97.4 TYP
SPLITTER INV 97.6
1000 GAL TANK INV 97.7
1000 GAL TANK INV 97.8
97.0


EVAPORATION-TRANSPIRATION TRENCH DETAIL



APPROVED
SIDE LINES & SET BACK
PERRY TOWNSHIP ZONING
PERMIT NO. 4581
ZONING INSPECTOR Dave King

STATE OF OHIO
THOMAS MARC COFFMAN
6857
REGISTERED
SURVEYOR

MARCH 5, 1992

I, the undersigned surveyor certify that this topography, indicated by 1' contours, and elevations shown hereon represent an actual field survey made by me on MARCH 2, 1992 and that the elevations were taken at appropriate intervals and that as of that date they existed as indicated hereon.

J. M. Coffman PS
No 6857

Grading Plan Approved
as shown and/or noted
THOMAS P. GILLES, P.E.
Lake County Engineer
By TPH Date 3/6/92

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date March 13, 1992
JOEL LUCIA, R.S., M.P.H.
Health Commissioner
BY Nancy Nibbs

SEWAGE DISPOSAL PERMIT MUST BE OBTAINED BY A LAKE COUNTY LICENSED INSTALLER BEFORE INSTALLATION IS STARTED.

LOW YIELD WATER FIXTURES REQUIRED ON ALL:
— Shower Head
— Toilet
— _____

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover
" "
B. No footer drains or downspouts to be discharged into septic tanks
C. All waste water to be discharged into septic tanks

VILLAGE SURVEYING CO.
252 THIRD ST. FAIRPORT HBR., OHIO 44077
(216) 357-1359