SITE PLAN
FOR
ANGELORO CONST CO
BEING PARCEL '4' OF COLLINS SPLIT
SOUTH RIDGE RD., IN THE TOWNSHIP OF
PERRY, COUNTY OF LAKE, STATE OF OHIO.

1" = 20'

EXIST. PROP.

EXIST. PROP.

BENCHMARK - 100.00 (ASSUMED)
NAIL IN RUBB RR. # 565

S 27° 30' 00" E 306.28'

PARCEL 'S' - 0.7064 Ac.

DUPLICATION AREA

8' TYP

6 LINES @ 75'

N 27° 30' 00" W 100.04'

N 62° 30' 00" E 309.19'

S 62° 30' 00" W 100.00'

Rad 101.0

16' CONC D/W

3 BR Split
FF - 102.50

42'

22'

11'

54'

28'

100'R

Prop. Well
A municipal supply has been applied for

Reviewed and Accepted
LAKE COUNTY GENERAL HEALTH DISTRICT
Date March 13, 1992
JOEL LUCIA, R. S., M. P. H.
Health Commissioner
BY Nancy Niehus

STATE OF OHIO
THOMAS MARC COLEMAN
7355
REGISTERED

FEB. 10, 1992

Grading Plan Appr
as shown and/or n
THOMAS P. GILL
Lake County Engi
By _____ Da

ODOT PERMIT REQUIRED

APPROVED
SIDE LINES & SET B
PERRY TOWNSHIP ZO
PERMIT NO. 46
ZONING INSPECTOR
Doug Pa

34" MIN.
TOPSOIL (6" MIN)
STRAW
4" PERF PIPE
3/4" GRAVEL
LEACH FIELD

HYDRAULIC PROFILE
VERT 1" = 3' HORZ 1" = 30'
3 BEDROOM

(2) DIST BOXES INV 98.0
SPLITTER INV 98.1
1000 GAL TANK INV 98.2
FF - 102.0

LOW YIELD WATER FIXTURES REQUIRED ON ALL:
Shower Head
Toilet

SEWAGE DISPOSAL PERMIT MUST BE OBTAINED BY A LAKE COUNTY LICENSED INSTALLER BEFORE INSTALLATION IS STARTED.

I, the undersigned hereby certify that this topography, indicated by 1' contours, and elevations shown hereon represent an actual field survey made by me on JAN 23, 1992 and that the elevations were taken at appropriate intervals and that as of that date they existed as indicated hereon.

J. M. Coffman PS No. 6857

A. To be brought to finished grade
1. Septic tank manhole covers
2. Splitter box cover
3. Distribution box cover

B. No footer drains or downspouts to be discharged into septic tanks
C. All waste water to be discharged into septic tanks

45 63

VILLAGE SURVEYING CO
202 THIRD ST, FAIRPORT HBR., OHIO
(216) 357-1359