

Reviewed and Accepted
 LAKE COUNTY GENERAL HEALTH DISTRICT
 Date 3-10-88
 JOEL LUCIA, R. S., M. P. H.
 Health Commissioner
 BY *Susan Erkkila*

- A. To be brought to finished grade
1. Septic tank manhole covers
 2. Splitter box cover
 3. Distribution box cover
- B. No footer drains or downspouts to be discharged into septic tanks
- C. All waste water to be discharged into septic tanks

LOW YIELD WATER
 FIXTURES REQUIRED
 ON ALL:
 Shower Head
 Toilet

SEWAGE DISPOSAL PERMIT MUST BE
 OBTAINED BY A LAKE COUNTY LICENSED
 INSTALLER BEFORE INSTALLATION IS
 STARTED.

2 PH 302

Grading Plan Approved
 as shown and/or noted
 THOMAS P. GILLES, P.E.
 Lake County Engineer
 BY *TPG*
 3/10/88

